



RoHS Declaration of Conformity

Name : Selec Controls Pvt.Ltd.
Address : EL-27/1,Electronic Zone, TTC industrial Area,
Mahape,Navi Mumbai,India -400710.

Declare under sole responsibility that the following described products

Product Name : **Current Protection Relay**

Model Type : **900CPR-3-230V-CE**

was affixed with RoHS marked in the year: **2014**

To which this declaration relates is in compliance with Directive 2011/65/EU of the European Parliament and of the council of 8 June 2011 on the restriction of the use of certain hazardous substances in electrical and electronic equipment (RoHS Directive) in accordance with the definitions set forth in the directives.

RoHS Restricted substance	Maximum Control Value
Lead	0.10% by weight (1,000 ppm) ²
Mercury	0.10% by weight (1,000 ppm)
Cadmium	0.01% by weight (100 ppm)
Hexavalent Chromium	0.10% by weight (1,000 ppm)
Polybrominated Biphenyls (PBB)	0.10% by weight (1,000 ppm)
Polybrominated diphenylethers (PBDEs) including Deca-BDE or pentaBDE or octaBDE	0.10% by weight (1,000 ppm)

The Technical construction file is maintained at Selec Controls Pvt Ltd, Navi Mumbai, India.

Selec Controls Pvt. Ltd. Mumbai India

Mrs. Priti Shetty (Head Of The Department)

(Place of Issue)

(Name & Designation of The Authorised Person)

7th July 2014

Ms. Manisha Khanna

(Date of issue)

(Signature of The Authorised Person)

Certificate no: Selec / RoHS / 2014 / PR Version 1.0